

MURRAY RIVER

GENERAL ARRANGEMENT PLAN  
SCALE 1:250

GENERAL NOTES:

- OPTION 1A - 500 MI/d BASE CAPACITY WITH EXPANSION TO 750MI/d;  
- 4 No. PERMANENT PUMPS AT 144 MI/d EACH,  
- 2 No. WARANGA PUMPS AT 100 MI/d EACH,  
- TOTAL STATION CAPACITY = 776MI/d.

31-21413-C001

A		CONCEPT DESIGN - ISSUED FOR COMMENT	LFM	KVL	09.10.09
NO.		REVISIONS	DRAWN	CHECK	APP'D

FULL SIZE ON ORIGINAL 0 2 4 6 8 10 cm

**COPYRIGHT**  
The concepts and information contained in this document are the copyright of GHD Pty Ltd and are only to be used in accordance with the terms of Agreement with Goulburn-Murray Water. Use or copying of the document by a third party in whole or part without the written permission of GHD Pty Ltd constitutes an infringement of copyright

Plot Date: 9 October 2009 - 4:55 PM

Plotted by: Bradley Davis, ###

0 2 4 6 8 10m  
SCALE 1:200 AT ORIGINAL SIZE



DRAWN	L. MATTHEWS	DESIGNED	APPROVED (CONSULTANT)
DRAFTING CHECK	DESIGN CHECK	DATE	






MANAGER ASSET SERVICES (TATURA)

GOULBURN-MURRAY WATER  
HATTAH LAKES FLOOD MANAGEMENT  
GENERAL ARRANGEMENT PLAN - OPTION 1A

GMW CORR. NO.	GOULBURN MURRAY RURAL WATER AUTHORITY 40 CASEY STREET (PO BOX 165), TATURA VIC. 3616 Telephone (03) 5833 5500 Fax (03) 5833 5501	SIZE A1	CAD DRAWING NO. 31-21413-C001	SHEET NUMBER 1 OF 1	DRAWING NUMBER	REV: A
---------------	--	------------	----------------------------------	------------------------	----------------	-----------

Plotted mm = Drawing units



TOLERANCES UNLESS NOT OTHERWISE						Scale			
GENERAL DIMENSIONS	MACHINING DIMENSIONS	SLOT SIZE	FLATNESS	END FITTING ALLOWANCE	END FITTING CONCENTRICITY	 A Weathercraft Company			
0-500 ±.004	X ±.01	SCREEN DIA ±.005	SCREEN SURFACE ±.004	+ .004 PER SIDE - .004 PER SIDE	1:50				
1000-3000 ±.006	X/X ±.01	OVERALL DIMENSIONS ±.006	OVERALL SURFACE ±.006	PER SIDE ±.004	1:50				
OVER 3000 ±.008	X/X ±.02	OVERALL DIMENSIONS ±.008	SURFACE TEXTURE 3.2	GAP BETWEEN SCREENS ±.004	1:50				
ANGLES ±.01	X/X ±.005	OVERALL DIMENSIONS ±.005	OVERALL SURFACE ±.005	PER SIDE ±.004	1:50				
THIS DRAWING AND ALL INFORMATION CONTAINED THEREIN REMAINS THE PROPERTY OF JOHNSON SCREENS PVT. LTD. IT IS CONFIDENTIAL AND MAY NOT BE MADE PUBLIC OR COPIED IT IS MADE AVAILABLE SUBJECT TO THE RETURN OF DRAWINGS. IT IS NOT TO BE USED, DIRECTLY OR INDIRECTLY, IN ANY WAY DETRIMENTAL TO THE INTERESTS OF JOHNSON SCREENS. INFRINGEMENTS OF THESE CONDITIONS WILL ATTRACT CLAIMS OF COMPENSATION.						Drawn	date	Title	
						GW	date	RIVER LAYOUT FOR	
						Manufacturing	date	T-72 PASSIVE INTAKE SCREENS	
						Plant/Working	date		
						Approval	date	Client	
								GOULBURN-MURRAY WATER	
DRAWN TO AS1100 - 3RD ANGLE PROJECTION - DO NOT SCALE DIMENSIONS IN MILLIMETRES UN.O. - BREAK ALL SHARP EDGES						Size	Drp No	Sheet	Rev
						Usf a1	03_86706	-	0
						Female (USDF) 03_86706			